

	<b>110</b>	<b>&gt; 6*</b>	<b>Modern</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>111</b>	<b>97</b>	<b>Calculated</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>212</b>	<b>80</b>	<b>Measured</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>213</b>	<b>74</b>	<b>Measured</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>214</b>	<b>56</b>	<b>Measured</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>313</b>	<b>73</b>	<b>Measured</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>314</b>	<b>51</b>	<b>Measured</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>315</b>	<b>&gt; 6*</b>	<b>Modern</b>	<b>No</b>
<b>Beanish Moor Hill</b>	<b>316</b>	<b>87</b>	<b>Calculated</b>	<b>No</b>
<b>Biosciences Complex</b>	<b>1101</b>	<b>185</b>	<b>Measured</b>	<b>No</b>
<b>Biosciences Complex</b>	<b>1102</b>	<b>176</b>	<b>Measured</b>	<b>No</b>
<b>Biosciences Complex</b>	<b>1311</b>	<b>&gt; 6*</b>	<b>Modern</b>	

**B   Ê   fl**                      **232**                      **> 6\***                      **Modern**                      **No**

**ciences Complex**

<b>Botterell Hill</b>	<b>508</b>	<b>112</b>	<b>Calculated</b>	<b>No</b>
<b>Botterell Hill</b>	<b>509A</b>	<b>76</b>	<b>Measured</b>	<b>Yes</b>
<b>Botterell Hill</b>	<b>816</b>	<b>163</b>	<b>Calculated</b>	<b>No</b>
<b>Botterell Hill</b>	<b>912</b>	<b>69</b>	<b>Calculated</b>	<b>No</b>
<b>Botterell Hill</b>	<b>B12E</b>	<b>52</b>	<b>Calculated</b>	<b>No</b>
<b>Botterell Hill</b>	<b>B13E</b>	<b>55</b>	<b>Measured</b>	<b>No</b>
<b>Botterell Hill</b>	<b>B14E</b>	<b>52</b>	<b>Measured</b>	<b>Yes</b>

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
<b>Botterell Hall</b>	<b>B14</b>	<b>196</b>	<b>Calculated</b>	<b>No</b>
<b>Botterell Hall</b>	<b>B15</b>	<b>91</b>	<b>Calculated</b>	<b>No</b>
<b>Buce Wing</b>	<b>13E</b>	<b>77</b>	<b>Calculated</b>	<b>No</b>
<b>Buce Wing</b>	<b>23E</b>	<b>72</b>	<b>Calculated</b>	<b>No</b>
<b>Buce Wing</b>	<b>23E</b>	<b>80</b>	<b>Calculated</b>	<b>No</b>
<b>Buce Wing</b>	<b>32E</b>	<b>70</b>	<b>Measured</b>	<b>Yes</b>
<b>Buce Wing</b>	<b>35E</b>	<b>51</b>	<b>Calculated</b>	<b>No</b>
<b>Buce Wing</b>	<b>45A</b>	<b>104</b>		



Building Name	Room Code	eACH	Source	HEPA Filter(s)
Dupuis Hall	B2E	13E	Calculated	No
Dupuis Hall	G01	137	Measured	No
Hills Hall	00E	100	Calculated	No
Hills Hall	08E	54	Measured	Yes
Hills Hall	08E	7E	Calculated	No
Hills Hall	09E	191	Calculated	No
Hills Hall	09E	72	Measured	Yes
Hills Hall	12E	71	Calculated	No
Hills Hall	15E	82	Measured	No
Hills Hall	21E	90	Calculated	No
Hills Hall	22E	90	Calculated	No
Hills Hall	23E	110	Calculated	No
Hills Hall	31E	12E	Calculated	No
Hills Hall	321	50	Measured	No
Hills Hall	321	70	Measured	No
Hills Hall	33E	127	Calculated	No
Rheington Hall	10B1	172	Measured	No
Faculty of Law- 128 Union St.	001	80	Measured	No
Faculty of Law- 128 Union St.	00E	87	Calculated	No
Faculty of Law- 128 Union St.	00E	140	Calculated	No
Faculty of Law- 128 Union St.	001	8E	Calculated	No
Faculty of Law- 128 Union St.	201	10E	Measured	No
Faculty of Law- 128 Union St.	20E	160	Calculated	No
Faculty of Law- 128 Union St.	211	190	Calculated	No
Faculty of Law- 128 Union St.	301	112	Calculated	No
Faculty of Law- 128 Union St.	401	110	Calculated	No
Faculty of Law- 128 Union St.	51E	64	Calculated	No
Faculty of Law- 128 Union St.	001	80	Measured	No
Faculty of Law- 128 Union St.	212	50	Measured	Yes
Faculty of Law- 128 Union St.	21E	7E	Measured	No
Faculty of Law- 128 Union St.	214	102	Measured	No
Faculty of Law- 128 Union St.	214	81	Measured	No
Faculty of Law- 128 Union St.	214	87	Measured	No
Faculty of Law- 128 Union St.	214	80	Measured	No
Hening Hall Jennett Wing	410	60	Calculated	No
Goodes Hall	101	> 6*	Modern	No
Goodes Hall	101	> 6*	Modern	No
Goodes Hall	10E	> 6*	Modern	No
Goodes Hall	10E	> 6*	Modern	No
Goodes Hall	10E	80	Measured	No
Goodes Hall	11E	87	Measured	No
Goodes Hall	121	> 6*	Modern	No
Goodes Hall	141	90	Measured	No
Goodes Hall	151	91	Measured	No
Goodes Hall	15E	90	Measured	No
Goodes Hall	301	> 6*	Modern	No



Building Name	Room Code	eACH	Source	HEPA Filter(s)
Harrison LeGare Hall	214	127	Calculated	No
Harrison LeGare Hall	221	77	Calculated	No
Harrison LeGare Hall	222	77	Calculated	No
Harrison LeGare Hall	223	77	Calculated	No
Harrison LeGare Hall	224	159	Calculated	No
Harrison LeGare Hall	225	82	Calculated	No
Harrison LeGare Hall	226	85	Calculated	No
Harrison LeGare Hall	301	99	Calculated	No
Harrison LeGare Hall	302	86	Calculated	No
Harrison LeGare Hall	303	86	Calculated	No
Harrison LeGare Hall	304	101	Calculated	No
Harrison LeGare Hall	311	86	Calculated	No
Harrison LeGare Hall	312	93	Calculated	No
Harrison LeGare Hall	313	85	Calculated	No
Harrison LeGare Hall	314	99	Calculated	No
Humphrey Hall	102	102	Measured	No
Humphrey Hall	131	110	Calculated	No
Humphrey Hall	132	106	Calculated	No
Humphrey Hall	219	169	Calculated	No
Humphrey Hall	223	82	Calculated	No
Isabel Bader Centre	101	> 6*	Moldem	No

**Building Name**

**Room Code**

**eACH**

**Source**

**HEPA Filter(s)**

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
<b>Louise D Actor</b>	<b>111A</b>	<b>67</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>111E</b>	<b>60</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>112</b>	<b>57</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>113</b>	<b>66</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>114</b>	<b>66</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>115</b>	<b>67</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>116</b>	<b>66</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>117</b>	<b>67</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>119</b>	<b>70</b>	<b>Calculated</b>	<b>No</b>
<b>Louise D Actor</b>	<b>1200E</b>	<b>57</b>	<b>Measured</b>	<b>Yes</b>
<b>Louise D Actor</b>	<b>1202I</b>	<b>53</b>	<b>Measured</b>	<b>Yes</b>
<b>Louise D Actor</b>	<b>1203E</b>			



Building Name	Room Code	eACH	Source	HEPA Filter(s)
Macintosh Cory Hill	D13	107	Calculated	No
Macintosh Cory Hill	E10	63	Calculated	No
Macintosh Cory Hill	E20	78	Calculated	No
Macintosh Cory Hill	E22	133	Calculated	No
Macintosh Cory Hill	E24	70	Calculated	No
Macintosh Cory Hill	E23	68	Calculated	No
Macintosh Cory Hill	E34	82	Calculated	No
McLaughlin Hill	10E	>6*	Modem	No
McLaughlin Hill	10E	11.7		

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
<b>Otaio Hill</b>	<b>10</b>	<b>6</b>	<b>Measured</b>	<b>Yes</b>





<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
----------------------	------------------	-------------	---------------	-----------------------